

# *Certificate of Performance*

*On this date the cleanroom facilities of*

*Oliver Healthcare Packaging Building 2*

*915 Pennsylvania Boulevard*

*Feasterville, PA 19053*

*Have been tested in accordance with NEBB Procedural Standards for Certified Testing of Cleanrooms to meet the following air cleanliness classification requirements of International Standard ISO 14644-1:2015 during the occupancy state noted.*

*Zone #11 Gowning Area - ISO Class 8 at 0.5, 1.0 & 5.0  $\mu\text{m}$  – At-Rest*

*Zone #11 Gowning Area - ISO Class 8 at 0.5, 1.0 & 5.0  $\mu\text{m}$  – Operational*

*Zone #12 Pouch Manufacturing Area - ISO Class 8 at 0.5, 1.0 & 5.0  $\mu\text{m}$  – At-Rest*

*Zone #12 Pouch Manufacturing Area - ISO Class 8 at 0.5, 1.0 & 5.0  $\mu\text{m}$  – Operational*

*NEBB Certified Firm: Air Filtration Management, Inc.*

*Phone: (610) 867-3869*

*[www.airfiltrationmgmt.com](http://www.airfiltrationmgmt.com)*

*NEBB Certification Number: 104*

*NEBB CPT Professional: Michael A. Wieder*

*Signature: *

*Test Date: June 2022      Retest Date: June 2023*

**National Environmental Balancing Bureau**

